

**Note: This detail applies to PVC
& PVC KEE systems only**

Note: This detail applies to PVC & PVC KEE systems only

6" MINIMUM
8" RECOMMENDED

4"

3" MIN.

1/4" MIN.

PENETRATION
(see note #3 for preparation)

PARAPRO 123 FLASHING SYSTEM or
PARAFLEX 531 LIQUID FLASHING (fully adhere)

PARASOLO MEMBRANE TARGET (see note #2)

PARAFAST FASTENERS/PLATES
(four fasteners & plates around penetration)

HEAT WELDED LAP (see note #1)

PARASOLO FLEECE-BACK MEMBRANE
(adhere to horizontal surfaces as shown)

INSULCEL LIGHTWEIGHT
INSULATING CONCRETE SYSTEM

STRUCTURAL SUPPORT

PARASOLO FLEXSEAL CAULK
GRADE SEALANT

PREPARED SUBSTRATE
(follow Siplast specifications)

1. FOR HEAT-WELDING LAPS USE 1" MINIMUM. WELD TO 1-1/2" MAXIMUM WELD.
2. PARASOLO PVC KEE MEMBRANE IS REQUIRED AT LOCATIONS TO RECEIVE PARAFLEX 531 LIQUID FLASHING SYSTEMS.
3. REFER TO SIPLAST PREPARATION GUIDELINES FOR PROPER SURFACE TREATMENT OF ALL MATERIALS PRIOR TO APPLICATION OF PARAPRO OR PARAFLEX 531 LIQUID FLASHING MATERIALS.
4. PENETRATIONS TO RECEIVE THE PARAPRO 123 FLASHING SYSTEM OR PARAFLEX 531 LIQUID FLASHING MUST BE SECURED TO THE STRUCTURE TO PREVENT MOVEMENT.
5. REQUIREMENTS AND RECOMMENDATIONS DETAILED IN CURRENT SIPLAST SPECIFICATIONS SHALL APPLY IN ADDITION TO THE ABOVE DRAWING.

Rev: 06.15.2023