

**Note: This detail applies to PVC
& PVC KEE systems only**

Penetration Detail: This detail applies to PVC KEE systems only

6" MINIMUM
8" RECOMMENDED

PRO PASTE

4"

3" MIN.

1/4" MIN.

PENETRATION (see note #3 for preparation)

PARAPRO 123 FLASHING SYSTEM or PARAFLEX 531 LIQUID FLASHING (fully adhere, see notes # 2 & 3)

PARASOLO KEE MEMBRANE TARGET (see note #2)

PARAFAST FASTENERS/PLATES (four fasteners & plates around penetration)

HEAT WELDED LAP (see note #1)

PARASOLO REINFORCED MEMBRANE

APPROVED COVERBOARD

STRUCTURAL SUPPORT

ROOF INSULATION

ROOF DECK/SUBSCRIBE

1. FOR HEAT-WELDING LAPS USE 1" MINIMUM. WELD TO 1-1/2" MAXIMUM WELD.
2. PARASOLO KEE MEMBRANE IS REQUIRED AT LOCATIONS TO RECEIVE PARAFLEX 531 LIQUID FLASHING SYSTEMS. PARAFLEX 531 LIQUID FLASHING CAN BE UTILIZED WITH PARASOLO PVC KEE ONLY.
3. REFER TO SIPLAST PREPARATION GUIDELINES FOR PROPER SURFACE TREATMENT OF ALL MATERIALS PRIOR TO APPLICATION OF PARAPRO OR PARAFLEX 531 LIQUID FLASHING MATERIALS.
4. PENETRATIONS TO RECEIVE THE PARAPRO 123 FLASHING SYSTEM OR PARAFLEX 531 LIQUID FLASHING MUST BE SECURED TO THE STRUCTURE TO PREVENT MOVEMENT.
5. REQUIREMENTS AND RECOMMENDATIONS DETAILED IN CURRENT SIPLAST SPECIFICATIONS SHALL APPLY IN ADDITION TO THE ABOVE DRAWING.

Rev: 06.22.2023